



NOT TO SCALE

NOTES

1. MAINTENANCE OF THE UTILITY SERVICE LINE SHALL BE THE RESPONSIBILITY OF THE LICENSEE.
2. UTILITY INSTALLATIONS SHALL BE IN ACCORDANCE WITH THE LATEST EDITION AND AMENDMENTS OF LOCAL AND STATE CODES. POWER LINES MUST BE INSTALLED A MINIMUM OF 30' ABOVE ANY DITCH, LATERAL, OR DRAIN. TELECOMMUNICATIONS AND CABLE TV MUST BE INSTALLED A MINIMUM OF 25' ABOVE ANY DITCH, LATERAL, OR DRAIN.
3. ALL GUY POLES AND GUY LINES SHALL BE OUTSIDE THE RIGHT-OF-WAY TO PREVENT INTERFERENCE WITH MAINTENANCE OPERATIONS.
4. BACKFILL FOR CUTS IN DISTRICT RIGHT-OF-WAYS SHALL BE COMPACTED TO NOT LESS THAN 90% OF THE MAXIMUM DRY DENSITY OF THE SOIL AS DETERMINED BY THE A.S.T.M. PROCTOR TEST.
5. UTILITY SERVICE LINES INSTALLED WITHIN FACILITY RIGHT-OF-WAYS SHALL BE INSTALLED WITHIN THE OUTSIDE 5' OF THE RIGHT-OF-WAY AND SHALL BE BURIED A MINIMUM OF 3' BELOW SURROUNDING NATURAL GROUND.
6. SEEDING OF DISTURBED AREAS WITHIN DISTRICT RIGHT-OF-WAYS IS REQUIRED PER THE ATTACHED SEEDING SPECIFICATION.



MRGCD  
STANDARD DETAIL

UTILITY 2

REV	DATE	DESCRIPTION	CHKD
LICENSE NO.		MAP NO.	DATE